


CAP 1" G WITH SHUT OFF VALVE FOR FUTURE

REF-1 SEE DETAIL SHEET M-4


SEE DETAIL SHEET M-4, TYP.

1/4", 3/8" R PIPING DOWN THROUGH ROOF. SEAL WATER TIGHT. AC-1 SET UNIT ON EQUIPMENT RAILS. SECURE TO ROOF FRAMING.

ROOF SCALE: 1/4"=1'-0"



- LEGEND:
- SUPPLY AIR REGISTER
 - RETURN AIR REGISTER
 - EXHAUST AIR REGISTER
 - FIRE DAMPER
 - THERMOSTAT
 - SENSOR
 - DUCT IONIZATION DETECTOR



MOULDS
MECHANICAL ENGINEERING
2190 WEST 11TH, SUITE 224
P.O. BOX 22238 EUGENE, OREGON 97402
PHONE: 541-484-0241

CRESWELL CITY HALL
13 SOUTH FIRST STREET - CRESWELL, OREGON

ROOF
HVAC PLAN

REVISION:
REVISION:
REVISION:
JOB: --
DATE: 8/01/08

M-3